

The Low Voltage Directive (LVD) 2014/35/EU and Electromagnetic Compatibility (EMC) Directive 2014/30/EU.

a) The manufacturer

Dinel, s.r.o.
U Tescomy 249
760 01 Zlín, Czech Republic

ID: 63476886
VAT: CZ63476886
web: www.dinel.cz

Tel.: +420 577 002 001
Fax: +420 577 002 007
E-mail: dinel@dinel.cz

b) The Products Covered by this Declaration

Hydrostatic Level Meter

HLM-35N

c) Product brief

Hydrostatic level meter type HLM-35N for continual level measurement of fluid compounds in non-pressure tanks, containers and pipes.

d) The Basis on which Conformity is being Declared

Electromagnetic compatibility: EN 61326-1
EN 55011 class B
EN 61000-4-2 class A
EN 61000-4-3 class A
EN 61000-4-4 class B
EN 61000-4-5 class B
EN 61000-4-6 class A
EN 61000-4-8 class A

e) Details of accredited person

Electromagnetic compatibility:
Accredited testing laboratory No. 1004.3, ITC, Sokolovská 573, 686 01 Uherské Hradiště, Czech Republic.
EMC protocol No. 414103420AE1 from 19. 4. 2017.

f) Ensure production quality

Manufacturer's quality management system was found conform with the requirements of ISO 9001: 2008. The company is holder of the certificate of quality management system, reg. number CZ – 2256/2012 dated 13.10.2015 and valid until 15.9.2018, issued by certification body CQS (IQNet). The certificate is valid for the development, manufacture and sales of electronic components and systems for measurement, control and industrial automation.

g) Manufacturer confirmation

The manufacturer identified in paragraph a) of this statement confirms that the properties of the product identified in point b) and c) of this declaration, meet the requirements, concretized in European technical standards identified in paragraph d) of this statement.

The product is under manufacturer's intended use safe. The manufacturer confirms that he has taken actions to ensure conformity of all products put on the market with technical documentation and the basic requirements.

Issued in Zlín, on 22.03.2017



Ing. Dalibor Štverka, Ph.D.
General manager